

**Florida Power & Light Company**  
**Statistics**  
(unaudited)

Periods Ended December 31	Quarter			Year-to-Date		
	2024	2023	% change	2024	2023	% change
<b>Energy sales (million kWh)</b>						
Residential	16,609	15,763	5.4 %	70,894	70,206	1.0 %
Commercial	12,987	12,700	2.3 %	53,138	52,507	1.2 %
Industrial	1,198	1,141	5.0 %	4,841	4,617	4.8 %
Public authorities	115	121	(4.4)%	446	505	(11.8)%
Increase (decrease) in unbilled sales	(1,606)	(1,034)	55.3 %	96	(314)	(130.7)%
Total retail	29,303	28,691	2.1 %	129,416	127,523	1.5 %
Electric utilities	2,120	1,691	25.4 %	8,965	8,520	5.2 %
Interchange power sales	916	1,466	(37.5)%	3,559	4,294	(17.1)%
<b>Total</b>	<b>32,339</b>	<b>31,848</b>	<b>1.5 %</b>	<b>141,941</b>	<b>140,337</b>	<b>1.1 %</b>

<b>Average price (cents/kWh)<sup>(1)</sup></b>						
Residential	13.39	14.97	(10.6)%	13.70	14.92	(8.2)%
Commercial	10.45	11.33	(7.8)%	10.62	11.38	(6.7)%
Industrial	7.71	8.42	(8.4)%	8.03	8.67	(7.4)%
<b>Total</b>	<b>11.52</b>	<b>12.77</b>	<b>(9.8)%</b>	<b>11.83</b>	<b>12.82</b>	<b>(7.7)%</b>

<b>Average customer accounts (000s)</b>						
Residential	5,325	5,214	2.1 %	5,288	5,179	2.1 %
Commercial	654	644	1.5 %	650	643	1.2 %
Industrial	14	16	(10.7)%	15	16	(3.0)%
Other	7	7	5.9 %	7	7	5.3 %
<b>Total</b>	<b>6,000</b>	<b>5,881</b>	<b>2.0 %</b>	<b>5,960</b>	<b>5,845</b>	<b>2.0 %</b>

	Periods Ended December 31		
	2024	2023	% change
<b>End of period customer accounts (000s)</b>			
Residential	5,331	5,222	2.1 %
Commercial	654	644	1.5 %
Industrial	14	16	(10.7)%
Other	7	7	6.0 %
<b>Total</b>	<b>6,006</b>	<b>5,889</b>	<b>2.0 %</b>

	2024	Normal	2023
<b>Three Months Ended December 31</b>			
Cooling degree equivalent days <sup>(2)</sup>	336	318	330
Heating degree equivalent days <sup>(2)</sup>	102	110	81
<b>Year-to-Date December 31</b>			
Cooling degree equivalent days <sup>(2)</sup>	2,232	2,026	2,365
Heating degree equivalent days <sup>(2)</sup>	291	366	181

(1) Excludes interchange power sales, net change in unbilled revenues and deferrals under cost recovery clauses.

(2) Cooling degree equivalent days use a 72 degree base temperature and heating degree equivalent days use a 66 degree base temperature.